

HEALTH FACILITY CONSTRUCTION FREQUENTLY ASKED QUESTIONS

STRUCTURAL

Anchorage

1. What are the anchorage requirements for CHEMPACK containers located within a hospital building?

Because of the size of the CHEMPACK container the California Building Code Section 1623A.1, Table A-O, Footnote 24 requires that it be restrained to prevent access movement during a seismic event. Below is a suggested detail for restraining the container:

